



IMC 301: listed is not installed. Standard + edition → cert ID → exact model → manufacturer-instruction page. If any link is missing, expect the redline.

Original Masterbuild PE packet from Daily Code Talk on 2024 IMC 301. Confirm the adopted edition. This is not an equipment schedule for your project. Pairs with NEC Article 100: a listing mark is not a blank check.

- ☐ **301.1: if it is IMC-regulated equipment, 301 applies. 301.2: economizers, demand-control ventilation, resets, and variable-**
301.3–301.5: traceable materials. Plastics: NSF 14 certified. Show the standard, edition, and a real cert/report ID.
- ☐ **301.6: gas piping, gas appliances, and venting per the International Fuel Gas Code. 301.7–301.9: listed for the application**
301.10–301.11: NFPA 70 for wiring/controls; International Plumbing Code for potable/drainage. 301.12: correct fuel; conversions/derates only per manufacturer instructions.
- ☐ **301.13: spring isolation needs supplemental restraint (snubbers / limit cables). 301.14: repairs preserve the original listing**
301.15–301.18: wind, flood, seismic per the International Building Code — including flood elevations and coastal breakaway walls.

The fail we see first

Springs without snubbers. A 60-second sweep on every scheduled item: standard+edition, cert ID, exact model, vent per manufacturer instructions, fuel/altitude, restraint. Missing one link is the comment.

What to send: the equipment schedule and whether isolation, flood, or gas appliances are on the job.

Send the comments. Not the County guideline.

Folio (does it start with 30?), process or UP number, and the comments PDF. Masterbuild will say which row is actually open.

masterbuildconsulting.com/send/

+1 (786) 398-6940 · Calendly: 30-minute scoping call

Masterbuild provides engineering services under a written scope. Not an equipment schedule. NSF 14 is Daily Code Talk education. Confirm adopted 301. This is not legal advice.