



Listed and labeled in accordance with ASTM E1509 and installed in accordance with the terms of the listing. The code does not give generic installation dimensions here.

Original Masterbuild PE packet from Daily Code Talk #170 on 2024 IMC 904. Confirm the adopted edition. Distinct from 903 factory-built fireplaces and 905 fireplace stoves. This is not an appliance selection. Do not invent hearth dimensions that Daily Code Talk did not publish.

☐ **Identify manufacturer and model. A generic “pellet stove” note is the comment.**

Installation criteria come from the listing, not from a copied 905 hearth detail.

☐ **Solid-fuel flue is still 801.11 — dedicated. Reuse is still 801.18.**

A pellet appliance on a shared gas flue is a different miss.

☐ **Do not copy Type B vent notes onto a pellet appliance.**

The listing writes the vent. Convenience does not.

The fail we see first

Schedule says “pellet stove,” no model, no ASTM E1509. Reviewer and contractor guessing the approved system.

What to send: manufacturer, model, and the listing sheet.

Send the comments. Not the County guideline.

Folio (does it start with 30?), process or UP number, and the comments PDF. Masterbuild will say which row is actually open.

masterbuildconsulting.com/send/

+1 (786) 398-6940 · Calendly: 30-minute scoping call

Masterbuild provides engineering services under a written scope. Not an appliance selection. Confirm adopted 904. This is not legal advice.