



Temporary power is a permitted system with a duration and a removal plan. It is not FPL dropping the service for a repair.

Original Masterbuild PE packet. Not a copy of the County electrical-inspection.pdf. Daily Code Talk on IMC 110: do not assume a universal 180-day limit for temporary systems. Construction power, a temp pole, a generator for construction, and a work-with are four different doors. We do not invent Article 110 working-space numbers. We do not quote temp-power fee dollars.

Which door

☐ **Work-with: existing service, FPL drops and picks up while you repair.**

Thirty-day clock. Access every panel. Tampering is a whole-building walk. See the work-with packet. That is not temp power.

☐ **Temporary power / construction service: a system that is not the permanent service.**

AHJ may authorize temporary service utilities. Name the duration, the load, the grounding, who removes it, and what happens if the permanent service is delayed. A cardboard panel on a stick with no duration is not a plan.

☐ **A generator for construction is still equipment with listing, grounding, and exhaust.**

It is not 'we will just plug into the house.' Fuel, exhaust, and working space are still live. Confirm the adopted electrical and mechanical sections.

☐ **Temp power still needs a permit row when the County says it does.**

See the fee navigator for which application — we do not quote dollars. Same-amperage AC still needs a mechanical permit. HB 803 did not exempt mechanical, and it did not exempt temporary electrical either just because it is temporary.

The fail we see first

Called as a work-with, actually a new temp pole, FPL will not pick up what was never dropped, and the 180-day building permit is a different clock from the temporary-system duration. Two clocks, one wasted truck.

What to send

Whether this is construction power, a generator, or a work-with on an existing service, plus duration and who removes it.

Send the comments. Not the County guideline.

Folio (does it start with 30?), process or UP number, and the comments PDF. Masterbuild will say which row is actually open.

masterbuildconsulting.com/send/

+1 (786) 398-6940 · Calendly: 30-minute scoping call

Masterbuild provides engineering services under a written scope. Nothing in this packet is a temporary-power permit, a utility authorization, or a representation about passing. Confirm the live County electrical inspection guideline and the adopted NEC edition. This is not legal advice.