



NEC Article 100: a listing mark is not a blank check. Approved, listed, labeled, and identified answer four different questions. They overlap. They are not synonyms.

Original Masterbuild PE packet from Daily Code Talk Sparky Edition on 2026 NEC Article 100 terminology. Confirm the adopted edition. This is not a product listing. Pairs with IMC 301 listed is not installed.

☐ **Approved — acceptability to the AHJ.**

Listed — inclusion in a published list by an organization acceptable to the AHJ after evaluation for a stated purpose.

☐ **Labeled — the label, symbol, or identifying mark carried by the product.**

Identified — suitability for the specific purpose, function, use, environment, or application the Code requires.

☐ **“Is it listed?” can miss the listing basis, the required mark, environmental suitability, compatibility with the equipment se**

If the original mark is missing, the enclosure has been altered, or the installation differs from the evaluated arrangement, photograph it, name the unknown, and route it to the responsible professional, manufacturer, qualified evaluator, or AHJ.

The fail we see first

Modified enclosure, missing mark. The schedule says “listed” and the field unit is cut. Do not convert an unresolved product question into a generic note.

What to send: the nameplate photo (safe access), the intended use/environment, and whether the enclosure was modified.

Send the comments. Not the County guideline.

Folio (does it start with 30?), process or UP number, and the comments PDF. Masterbuild will say which row is actually open.

masterbuildconsulting.com/send/

+1 (786) 398-6940 · Calendly: 30-minute scoping call

Masterbuild provides engineering services under a written scope. Not a product listing. Confirm the adopted NEC edition. This is not legal advice.